

DOP-004-CPR-2013 MODEL NO

Declaration of Performance English 2



DOP Ref: DoP-004-CPR-2013

Revision: 02 Date: 12.05.2021 Page **1** of **3**





DECLARATION OF PERFORMANCE

DoP-004-CPR-2013

1. Unique identification code of the

Authorised Representative:

product-type:

NFS2, NFS4, NFS8 and NFS8V

Intended Use: Fire detection and fire alarm systems installed in and around buildings

3. Manufacturer by: Honeywell Life Safety Romania

Salcimilor Street, No. 2bis 305500, Lugoj Jud. Timis

4. Design authority: Notifier by Honewell

(Pittway Systems Technology Group Europe Ltd)

Honeywell Life Safety Systems

140 Waterside Road

Hamilton Industrial Estate Leicester, LE5 TN

United Kingdom Not applicable

6. System of AVCP: System 1

7a Harmonised Standard: EN 54-2: 1997+A1:2006,

EN 54-4:1997 + A2: 2006

Notified Body Number: 0786

0786 - CPD - 20797

7b European Assessment Document: Not applicable

.

5.

European Technical Assessment: Not applicable Technical Assessment Body: Not applicable

Notified Body: VdS Schadenverhütung GmbH

8. Declared Performance:

EN 54-2: Fire Detection and Fire Alarm Systems – Control and Indicating Equipment		
Clause	Description	Performance
4,5,6,7,8,9, 10,11,12,13,14	Operational reliability	Pass
15.4	Durability of operational reliability Temperature resistance	Pass
15.6, 15.7, 15.15	Durability of operational reliability Vibration resistance	Pass
15.8 to 15.13	Durability of operational reability Electrical stability	Pass
15.5, 15.14	Durability of operational reability Humidity resistance	Pass
4, 5, 7	Performance under fire condtions	Pass
7.1, 7.7, 7.11, 7.12	Response delay (response time to fire)	Pass

EN 54-4: Fire Detection and Fire Alarm Systems – Power supply equipment		
Clause	Description	Performance
4,5,6,7,8	Operational reliability	Pass
9.5	Durability of operational reliability	Pass
	Temperature resistance	
9.7, 9.8, 9.15	Durability of operational reliability	Pass
	Vibration resistance	
9.9 to 9.13	Durability of operational reability	Pass
	Electrical stability	
9.6, 9.14	Durability of operational reability	Pass
	Humidity resistance	

DOP Ref: DoP-004-CPR-2013

Revision: 02 Date: 12.05.2021 Page **2** of **3**







4, 5, 6 Performance of power supply Pass

9 Appropriate Technical Documentation and/or Specific Technical Documentation:

Not applicable

10. The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Souther


Signed for and on behalf of the manufacturer by:

Name and Function Chauhan Kishore

At:

On (Date): 12.05.2021

Signature:



Revision: 02 Date: 12.05.2021 Page **3** of **3**

