

DOP- N°007-CPR-2013  
MODEL NO

Declaration of Performance	English		2
----------------------------	---------	---	---

## DECLARATION OF PERFORMANCE

DoP-007-CPR-2013

1. Unique identification code of the product-type: ID300.ID3K2, IDBEK, ID3K4, ID3K6, ID3K8, PSU7A, PSU3 A, NF300, NF3000, NF500, NF5000, Mach2.8
2. Intended Use: Fire detection and fire alarm systems installed in and around buildings
3. Manufacturer by: Honeywell Life Safety Romania  
Salcimilor Street, No. 2bis  
305500, Lugoj Jud. Timis
4. Design authority: Notifier by Honewell  
(Pittway Systems Technology Group Europe Ltd)  
Honeywell Life Safety Systems  
140 Waterside Road  
Hamilton Industrial Estate Leicester, LE5 TN  
United Kingdom
5. Authorised Representative: Not applicable
6. System of AVCP: System 1
- 7a Harmonised Standard: EN 54-2: 1997+A1:2006,  
EN 54-4:1997 + A2: 2006
- Notified Body Number: 0786  
0786 – CPR - 20878
- 7b European Assessment Document: Not applicable
- European Technical Assessment: Not applicable
- Technical Assessment Body: Not applicable
- Notified Body: VdS Schadenverhütung GmbH
8. Declared Performance:

<b>EN 54-2: Fire Detection and Fire Alarm Systems – Control and Indicating Equipment</b>		
<b>Clause</b>	<b>Description</b>	<b>Performance</b>
4,5,6,7,8,9, 10,11,12,13,14 15.4	Operational reliability	Pass
15.4	Durability of operational reliability	Pass
15.6, 15.7, 15.15	Temperature resistance	Pass
15.6, 15.7, 15.15	Durability of operational reliability	Pass
15.8 to 15.13	Vibration resistance	Pass
15.8 to 15.13	Durability of operational reability	Pass
15.5, 15.14	Electrical stability	Pass
15.5, 15.14	Durability of operational reability	Pass
4, 5, 7	Humidity resistance	Pass
4, 5, 7	Performance under fire condtions	Pass
7.1, 7.7, 7.11, 7.12	Response delay (response time to fire)	Pass
<b>EN 54-4: Fire Detection and Fire Alarm Systems – Power supply equipment</b>		
<b>Clause</b>	<b>Description</b>	<b>Performance</b>
4,5,6,7,8	Operational reliability	Pass
9.5	Durability of operational reliability	Pass
9.5	Temperature resistance	Pass
9.7, 9.8, 9.15	Durability of operational reliability	Pass
9.7, 9.8, 9.15	Vibration resistance	Pass
9.9 to 9.13	Durability of operational reability	Pass
9.9 to 9.13	Electrical stability	Pass
9.6, 9.14	Durability of operational reability	Pass
9.6, 9.14	Humidity resistance	Pass
4, 5, 6	Performance of power supply	Pass



9 Appropriate Technical Documentation and/or Specific Technical Documentation: Not applicable

10. The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:

Name and Function Chauhan Kishore

At:

On (Date): 12.05.2021

Signature: